




Yallaroi Creek

EPA ID	Frequency Required under EPL	Location	Day	Month	Year	pH	Electrical Conductivity dS/m	Electrical Conductivity µS/cm	Total Suspended Solids mg/L	Total Phosphorous mg/L-P	Reactive Phosphorous mg/L-P	Reactive Phosphorous mg/L	Total Nitrogen mg/L	Total Kjeldahl Nitrogen mg/L	Nitrate mg/L-N	Nitrate mg/L	Ammonium Nitrogen mg/L	Potassium mg/L	Chloride mg/L	Flow (Estimate)	
14	Special 3	Yallaroi Creek Downstream	19	January	2015	7.9		480	29	1	0.1	0.31	8	2	29	128.47	0.1		36		
14	Special 3	Yallaroi Creek Downstream	26	May	2015	8.9		650	15	1	0.1	0.31	2	2	1	4.43	0.2	9	170		
13	Special 3	Yallaroi Creek Upstream	19	January	2015	7.8		510	49	1	0.2	0.61	4	3	4.4	19.492	0.1		43		
13	Special 3	Yallaroi Creek Upstream	26	May	2015	8.7		1100	16	1	0.1	0.31	2	2	2.1	9.303	0.2	9	160		
14	Special 3	Yallaroi Creek Downstream	22	January	2016	7.4		520	23	1	0.3	0.92	2	2	1	4.43	0.5	8	57		
13	Special 3	Yallaroi Creek Upstream	22	January	2016	7.7		490	100	1	0.3	0.92	2	2	1	4.43	0.2	7	48		
14	Special 3	Yallaroi Creek Downstream	16	June	2017	7.65		0.686	13	0.45	0.229	0.70	1.97	1.96	0.007	0.03101	0.748	6.6	51		
13	Special 3	Yallaroi Creek Upstream	16	June	2017	8.08		0.944	4	0.09	0.048	0.15	1.04	0.01	0.025	0.11075	0.102	8.1	103		
13	Special 3	Yallaroi Creek Upstream	10	August	2017	8.51		1583	5	0.05	0.018	0.06	0.73	0.73	0.005	0.02215	0.038	7.7	211		
13	Special 3	Yallaroi Creek Upstream	19	March	2018	7.15		346		0.63	0.486	1.49	1.86	1.85	0.005	0.02215	0.332				
14	Special 3	Yallaroi Creek Downstream	10	August	2017	8.01		1268	8	0.12	0.035	0.11	1.07	1.07	0.005	0.02215	0.046	8.3	183		
14	Special 3	Yallaroi Creek Downstream	19	March	2018	7.12		303	60	0.71	0.522	1.60	1.82	1.81	0.005	0.02215	0.111	8.5	32		
14	Special 3	Yallaroi Creek Downstream	1	August	2018	8.31		931	3	0.06	0.013	0.04	0.86	0.85	<0.005	<0.005	0.074	8.7	109		
14	Special 3	Yallaroi Creek Downstream	10	July	2019	8.03	0.396	396	31	0.19	0.053	0.16	2.38	2.22	0.151	0.66893	0.323	6.2	28.1	Stagnant	

**Special 3** Special 3 indicates special frequency 3 which is every 6 months AND in the event of an overflow from Main Holding Pond (EPA Point 1) and/or terminal ponds (EPA Points 3 and 5)

 Required to be reported under EPL

 No Data Available